

UNITED STATES MARINE CORPS  
Marine Corps Base  
Camp Lejeune, North Carolina 28542-5001

6280/A  
FAC

5 AUG 1985

FIRST ENDORSEMENT on N.C. Dept of Human Resources ltr of  
29 Jul 85

From: Assistant Chief of Staff, Facilities, Marine Corps Base,  
Camp Lejeune

To: Public Works Officer

Subj: REPLACE WATER SUPPLY WELL 615, CONTRACT NO. 85-6305

Encl: (1) N.C. Division of Health Services ltr dtd 29 Jul 85

1. Forwarded for development of the information as requested in the enclosure. Request ~~and~~ necessary response be prepared for Assistant Chief of Staff, Facilities, signature. Please advise this office by 8 August 1985 of the completion date of the sampling, lab analyses, and development of the information requested.

2. Point of contact for this matter is Mr. Bob Alexander, extension 3034.

B. W. ELSTON  
By direction

Copy to:  
→ MAIN  
NREAD

*Copy to  
Mr. Price  
8/13/85  
per*

CLW

0000001291



North Carolina Department of Human Resources  
Division of Health Services  
P.O. Box 2091 • Raleigh, North Carolina 27602-2091

James G. Martin, Governor  
Phillip J. Kirk, Jr., Secretary

Ronald H. Levine, M.D., M.P.H.  
State Health Director  
919/733-3446

July 29, 1985

Mr. R. A. Tiebout, Colonel  
Assistant Chief of Staff, Facilities  
By Direction of the Commanding General  
U. S. Marine Corps Base  
Camp Lejeune, North Carolina 28542

Re: Replacement of Water Well No. 615  
U. S. Marine Corps Base  
Camp Lejeune, N. C.  
Onslow County

Dear Colonel Tiebout:

Plan and specification for the referenced project have been reviewed by engineers of this Section and our comments are:

1. A copy of well site approval letter from our DHS Greenville Office must be submitted.
2. A chemical analysis report done by a certified lab must be submitted.
3. A biological test result must also be submitted to this office.
4. A well drill log including the 24 hour pumping test of the well must be furnished.
5. The well pump's manufacturer, model number and performance curve must be furnished.
6. The drainage from Diesel full tank foundation must be discharged 100 feet away.

We shall continue our review upon receipt of the aforementioned information and revisions. If you have any questions, please call us at (919) 733-2460.

**CLW**

**0000001292**

Sincerely,

A handwritten signature in dark ink, appearing to read "Heinrich S. Ou".

Heinrich S. Ou  
Environmental Engineer  
Engineering Planning Branch  
Environmental Health Section

CC: M. P. Bell

HSO/cj

06 AUG 1985

ROUTING IP

	ACTION	INFO	INITIAL
BMO		<del>✓</del>	<del>W</del>
ABMO		<del>✓</del>	<del>W</del>
ADMIN			
F&A			
MAINT NCO			
M&R			
OPNS			
PROP			
UMACS			
UTIL		✓	CSJ db
SECRETARY			

COMMENTS:

CLW

0000001293