

0473A

State of North Carolina
Department of Environment,
Health and Natural Resources
Division of Environmental Health
Public Water Supply Section



James B. Hunt, Jr., Governor
Jonathan B. Howes, Secretary
Linda C. Sewall, Director

December 10, 1996

Mr. Jim Mertsching, Contract Manager
Sauer, Incorporated
11223 Phillips Parkway Drive, East
Jacksonville, Florida 32256-1574

Re: Anthracite Media Sample #0171 15
Camp Lejeune Water Plant
U.S. Marine Corps Base
Onslow County, North Carolina

Dear Mr. Mertsching:

Results of analysis of the reference are as follows:

a.	Effective size	0.78
b.	Uniformity coefficient	1.51
c.	Dust content (%)	0.20

Based on the above information, this media is approved for its intended use.

Sincerely,

J. C. Lin, P.E., Head
Plan Review Branch
Public Water Supply Section

JCL:jp

cc: M. P. Bell, Regional Engineer
Onslow County Health Department
Camp Lejeune Marine Corps Base ✓

From: Pat Rapertz
12/16

CLW

0000002692

